



COUNTY #


SOIL PROFILE





204



202



SOIL PROFILE



INDICATE NORTH - NAME ADJOINING ROADWAY AS BASE LINE.

DATE	TEST NO.	DEPTH	PRE-WET		TEST - 1" DROP		TIME		
			START	STOP	START	STOP			
9/24/01	203	√12 1/2' 2 1/2'	10:51:00	10:53:40	10:53:46	10:57:40	4 min	OK	
	204	√14' 4 1/2'	11:09:40	11:11:20	11:11:26	11:15:30	4 min	OK	
	202	√14' 3'	11:17:30	Passed		11:21:40	2 min	OK	
	205	√14' 3' Reported Curie	11:26:00	11:28		11:30:10	2 min	OK	
	201	stopped @ 8' rock Mic	soils but too close to #17 to test						OK
	206	√13' 3 1/2'	11:58:40	12:00:40	12:00:40	12:08:20	5 1/2 min	OK	

REMARKS Test holes for center in bottom of reconfigured SBA's.

TYPE OF SOIL Manga Islandy


TESTED BY RJP ALSO PRESENT \_\_\_\_\_

TRENCH DESIGN DATA: AVERAGE PERCOLATION TIME \_\_\_\_\_ TRENCH WIDTH \_\_\_\_\_



INLET DEPTH \_\_\_\_\_ MAXIMUM BOTTOM DEPTH \_\_\_\_\_ SQ. FT./BEDROOM \_\_\_\_\_

COUNTY #



SOIL PROFILE



SOIL PROFILE



INDICATE NORTH - NAME ADJOINING ROADWAY AS BASE LINE.



DATE	TEST NO.	DEPTH	PRE-WET		TEST - 1" DROP		TIME	
			START	STOP	START	STOP		
10/16/00	6	v/3' 3 1/2	1:05	1:22:00	1:22:00	1:40	20min	OK
	3	v/3' 3'	1:15:00	1:22:00	1:22:00	1:39	17min	OK
	5	v/3' 4 1/2	1:26:00	1:36:00	1:36:00	1:53:00	17min	OK
	2	v/3' 3'	1:43:00	1:45	1:45	1:48:00	3min	OK
	1	v/3' 3'	1:57:30	2:03:00	2:03:00	2:17:0	14min	OK

REMARKS \_\_\_\_\_

TYPE OF SOIL loamy

TESTED BY Philip Day ALSO PRESENT \_\_\_\_\_

TRENCH DESIGN DATA: AVERAGE PERCOLATION TIME \_\_\_\_\_ TRENCH WIDTH \_\_\_\_\_

INLET DEPTH \_\_\_\_\_ MAXIMUM BOTTOM DEPTH \_\_\_\_\_ SQ. FT./BEDROOM \_\_\_\_\_

