

95
STATE OF MARYLAND
DEPARTMENT OF WATER RESOURCES
STATE OFFICE BLDG. ANNAPOLIS, MARYLAND 21401

WELL COMPLETION REPORT

FILL IN THIS FORM COMPLETELY

DATE WELL COMPLETED: 4/25/72
DEPTH OF WELL: 127 FEET
DRILLER'S IDENTIFICATION NO.: 251

OWNER: Chaper (LAST NAME)
STREET OR RFD: 251a Poplar Drive
CITY/TOWN/VILLAGE: Kail
COUNTY: Baltimore STATE: MD ZIP: 21207

WELL LOG

STATE THE KIND OF FORMATIONS PENETRATED, THEIR COLOR, DEPTH, THICKNESS AND IF WATER BEARING

DESCRIPTION (USE APPROPRIATE ABBREVIATIONS):
5 ft of dirt & 122 ft of Gray Rock

DEPTH (FEET):
FROM 0 TO 5
FROM 5 TO 10
FROM 10 TO 15
FROM 15 TO 20
FROM 20 TO 25
FROM 25 TO 30
FROM 30 TO 35
FROM 35 TO 40
FROM 40 TO 45
FROM 45 TO 50
FROM 50 TO 55
FROM 55 TO 60
FROM 60 TO 65
FROM 65 TO 70
FROM 70 TO 75
FROM 75 TO 80
FROM 80 TO 85
FROM 85 TO 90
FROM 90 TO 95
FROM 95 TO 100
FROM 100 TO 105
FROM 105 TO 110
FROM 110 TO 115
FROM 115 TO 120
FROM 120 TO 125
FROM 125 TO 130
FROM 130 TO 135
FROM 135 TO 140
FROM 140 TO 145
FROM 145 TO 150
FROM 150 TO 155
FROM 155 TO 160
FROM 160 TO 165
FROM 165 TO 170
FROM 170 TO 175
FROM 175 TO 180
FROM 180 TO 185
FROM 185 TO 190
FROM 190 TO 195
FROM 195 TO 200

CONCRETE RECORD

WELL HAS BEEN CEMENTED (CIRCLE APPROPRIATE BOX) YES NO

TYPE OF CEMENTING MATERIAL (CIRCLE ONE):
CEMENT C
DENSITIVE D
NO. OF BAGS: 7

CALLING OF WATER: 65

DEPTH OF GROUT SEAL (TO NEAREST FOOT):
FROM 0 FT. TO 20 FT.
(ENTER 0 IF FROM SURFACE)

CASING RECORD

INSERT APPROPRIATE CODE BELOW

STEEL: S T
CONCRETE: C O
PLASTIC: P L
OTHER: O Y

MAIN CASING TYPE: T

NORMAL DIAMETER TOP (NEAREST INCH): 6.0

TOTAL DEPTH OF MAIN CASING (NEAREST FOOT): 21

OTHER CASING (IF USED):
DIAMETER (INCH): DEPTH (FEET) FROM TO

SCREEN RECORD

INSERT APPROPRIATE CODE BELOW

STEEL: S T
BRASS OR OTHER: B R
OPEN HOLE: H O
PLASTIC: P L
OTHER: O Y

DEPTH (NEAREST WHOLE FOOT):
FROM TO

PUMPING TEST

WAS PUMPED (TO NEAREST HOUR): 3 1/2

PUMPING RATE (GALLONS PER MINUTE TO NEAREST GALLON): 5

METHOD USED TO MEASURE PUMPING RATE: LAND SURFACE

WATER LEVEL (DISTANCE FROM LAND SURFACE) IN FEET: 35

WELLING IN FEET: 90

TYPE OF PUMP USED (CIRCLE APPROPRIATE ONE) (FOR PUMPING TEST):
A AIR P PISTON T TURBINE
C CENTRIFUGAL R ROTARY O OTHER (SPECIFY)
J JET S SUBMERSIBLE

PUMP INSTALLED

TYPE OF PUMP (WRITE APPROPRIATE LETTER IN BOX - SEE ABOVE): A, C, J, P, R, S, T, O

DRILLER WILL INSTALL PUMP (CIRCLE APPROPRIATE BOX):
YES Y NO N

CAPACITY:
GALLONS PER MINUTE (TO NEAREST GALLON):

PUMP HORSE POWER:

PUMP COLUMN LENGTH (NEAREST FEET):

CASING HEIGHT (CIRCLE APPROPRIATE BOX AND ENTER CASING HEIGHT):
+ ABOVE LAND SURFACE:
- BELOW LAND SURFACE:

CIRCLE APPROPRIATE BOXES

A A WELL WAS ABANDONED AND SEALED WHEN THIS WELL WAS COMPLETED

E ELECTRIC LOG OBTAINED

P TEST WELL CONVERTED TO PRODUCTION WELL

I HEREBY CERTIFY THAT I HAVE COMPLIED WITH ALL CONDITIONS STATED ON THE ABOVE-CAPTIONED "PERMIT TO DRILL WELL", AND THAT INFORMATION CONTAINED IN THIS REPORT IS TRUE, ACCURATE, AND COMPLETE TO THE BEST OF MY KNOWLEDGE, INFORMATION AND BELIEF.

DRILLER'S NAME: Arthur A. Davidson

SIGNATURE: Arthur A. Davidson

DIAMETER OF SCREEN: (NEAREST INCH)

SCREEN PRICE:

IF WELL DRILLED WITH A FLOWING WELL, CIRCLE BOX: F

FOR USE ONLY (NOT TO BE FILLED IN BY DRILLER):
TELESCOPE CASING: T
LOG INDICATOR: L
OTHER DATA AVAILABLE: O

LOCATION OF WELL ON LOT

SHOW PERMANENT STRUCTURE SUCH AS BUILDINGS, SEPTIC TANKS, AND/OR OTHER LAND MARKS AND INDICATE NOT LESS THAN TWO DISTANCE MEASUREMENTS TO WELL.