

6532

STATE OF MARYLAND  
DEPARTMENT OF WATER RESOURCES  
STATE OFFICE BLDG. ANNEAPOLIS, MARYLAND

WELL COMPLETION REPORT

RECEIVED

DATE WELL COMPLETED  
3-16-73

DEPTH OF WELL  
100

DRILLER IDENTIFICATION NO.  
217

B-13

LAST NAME  
Empire

POST OFFICE  
Rockville Md.

WELL DESCRIPTION

WELL LOG

INDICATE KIND OF FORMATIONS PENETRATED, THEIR DEPTH, THICKNESS AND IF WATER BEARING

DESCRIPTION (ADDITIONAL SHEETS NECESSARY)	FEET		KIND OF WATER
	FROM	TO	
STATE 3 100			

GROUTING RECORD

WELL HAS BEEN GROUTED (CIRCLE APPROPRIATE BOX)  
 YES  NO

TYPE OF GROUTING MATERIAL (CIRCLE BOX)  
CEMENT  M  B BENTONITE CLAY

NO. OF BAGS 4 NO. OF POUNDS 376

BALLONS OF WATER 25

DEPTH OF GROUT SEAL (TO NEAREST FOOT)  
FROM 0 FT. TO 20 FT.

(ENTER 0 IF FROM SURFACE)

CASING RECORD

CASING TYPE (CIRCLE APPROPRIATE CODE)  
 ST STEEL  CO CONCRETE

PL PLASTIC  OT OTHER

MAIN CASING TYPE  ST

NOMINAL DIAMETER (TO NEAREST INCH) 6

TOTAL DEPTH OF MAIN CASING (TO NEAREST FOOT) 21

OTHER CASING (IF USED) DIAMETER DEPTH (FEET)

SCREEN RECORD

SCREEN TYPE (CIRCLE APPROPRIATE CODE)  
 ST STEEL  BR BRASS OR BRONZE  HO OPEN HOLE

PL PLASTIC  OT OTHER

DEPTH (NEAREST WHOLE FOOT) FROM TO

DIAMETER OF SCREEN (NEAREST INCH) FROM TO

GRAVE, PACE

IF WELL DRILLED WAS A FLOWING WELL, CIRCLE BOX   F

DATE USE ONLY (NOT TO BE FILLED IN BY DRILLER)

PUMPING TEST

HOURS PUMPED (TO NEAREST HOUR) 2

PUMPING RATE (GALLONS PER MINUTE TO NEAREST GALLON) 12

METHOD USED TO MEASURE PUMPING RATE ROTARY

WATER LEVEL (DISTANCE FROM LAND SURFACE) BEFORE PUMPING 35

WHEN PUMPING 100

TYPE OF PUMP USED (CIRCLE APPROPRIATE BOX)

A AIR  D PISTON  T TURBINE

C CENTRIFUGAL  R ROTARY  O OTHER (SPECIFY BELOW)

J JET  S SUBMERSIBLE

PUMP INSTALLED

DRILLER WILL INSTALL PUMP (CIRCLE APPROPRIATE BOX)  YES  NO

CAPACITY: GAL PER MINUTE (TO NEAREST GALLON) 31

PUMP HORSE POWER 37

PUMP COLUMN LENGTH (NEAREST FOOT) 43

CASING HEIGHT (CIRCLE APPROPRIATE BOX AND ENTER CASING HEIGHT)

ABOVE LAND SURFACE

BELOW LAND SURFACE

LOCATION OF WELL ON LOT

SHOW PERMANENT STRUCTURE SUCH AS BUILDINGS, SEPTIC TANKS, AND/OR OTHER LAND MARKS AND INDICATE NOT LESS THAN TWO DISTANCES (MEASUREMENTS TO WELL)

Diagram showing well location on lot with measurements to buildings and septic tanks.

CIRCLE APPROPRIATE BOXES

WELL WAS ABANDONED AND SEALED WHEN THIS WELL WAS COMPLETED

ELECTRIC LOG OBTAINED

COPY OF ELECTRIC LOG ATTACHED

I HEREBY CERTIFY THAT I HAVE COMPLIED WITH ALL CONDITIONS STATED ON THE ABOVE-CAPTIONED "PERMIT TO DRILL WELL", AND THAT INFORMATION CONTAINED HEREIN IS TRUE, ACCURATE, AND COMPLETE TO THE BEST OF MY KNOWLEDGE, INFORMATION AND BELIEF.

DRILLER'S NAME

Signature of Driller

DATE