

ONE 214 9/71

C 11 6975 (SEQ. NO.)

STATE OF MARYLAND
WATER RESOURCES ADMINISTRATION
TAWES STATE OFFICE BLDG., ANNAPOLIS, MD. 21401
WELL COMPLETION REPORT

THIS REPORT MUST BE SUBMITTED WITHIN 30 DAYS AFTER WELL COMPLETION

FILL IN THIS FORM COMPLETELY

COUNTY NUMBER

DATE RECEIVED (WRA USE ONLY)

DATE WELL COMPLETED Aug 5, 74

DEPTH OF WELL 16.5 (TO NEAREST FOOT)

PERMIT NO. FROM "PERMIT TO DRILL WELL" H C - 1 - C 775

DRILLERS IDENTIFICATION NO. 238

OWNER Residential Developers Inc.

LAST NAME FIRST NAME

STREET OR RFD 10210 Greenbelt Rd. POST OFFICE Sea Brook Md.

WELL LOG

STATE THE KIND OF FORMATIONS PENETRATED, THEIR COLOR, DEPTH, THICKNESS AND IF WATER BEARING.

DESCRIPTION (USE ADDITIONAL SHEETS IF NECESSARY)	FEET		CHECK IF WATER BEARING
	FROM	TO	
<u>Sand</u>	<u>0</u>	<u>4.2</u>	
<u>Thin Rock</u>	<u>4.2</u>	<u>16.5</u>	

GROUTING RECORD

WELL HAS BEEN GROUTED (CIRCLE APPROPRIATE BOX) YES NO

TYPE OF GROUTING MATERIAL (CIRCLE BOX):
 CEMENT BENTONITE CLAY

NO. OF BAGS 16 NO. OF POUNDS 1564

GALLONS OF WATER 96

DEPTH OF GROUT SEAL (TO NEAREST FOOT)
 FROM 0 FT. TO 37 FT.

CASING RECORD

CASING TYPES: STEEL CONCRETE PLASTIC OTHER

MAIN CASING TYPE S + T NOMINAL DIAMETER TOP (NEAREST INCH) 6 TOTAL DEPTH OF MAIN CASING (NEAREST FOOT) 45

OTHER CASING (IF USED)

DIAMETER (INCH) DEPTH (FEET) FROM TO

SCREEN RECORD

SCREEN TYPE OR OPEN HOLE: STEEL BRASS HD PL OT

PUMPING TEST

HOURS PUMPED (TO NEAREST HOUR) 2

PUMPING RATE (GALLONS PER MINUTE TO NEAREST GALLON) 6

METHOD USED TO MEASURE PUMPING RATE liters

WATER LEVEL (DISTANCE FROM LAND SURFACE) BEFORE PUMPING 35 (NEAREST FOOT)

WHEN PUMPING 15 (NEAREST FOOT)

TYPE OF PUMPED USED (CIRCLE APPROPRIATE BOX):
 AIR PISTON TURBINE
 CENTRIFUGAL ROTARY OTHER (DESCRIBE BELOW)
 JET SUBMERSIBLE

PUMP INSTALLED

TYPE OF PUMP (WRITE APPROPRIATE LETTER IN BOX - SEE ABOVE): A, C, J, P, R, S, T, O

DRILLER WILL INSTALL PUMP (CIRCLE APPROPRIATE BOX) YES NO

CAPACITY: GALLONS PER MINUTE (TO NEAREST GALLON) 31 35

PUMP HORSE POWER 37 41

PUMP COLUMN LENGTH (NEAREST FOOT) 43 47

CASING HEIGHT (CIRCLE APPROPRIATE BOX AND ENTER CASING HEIGHT):
 ABOVE BELOW 2 (NEAREST FOOT)

DEPTH (NEAREST WHOLE FOOT)

1 10 2 32 3 16.5

CIRCLE APPROPRIATE BOXES

A WELL WAS ABANDONED AND SEALED WHEN THIS WELL WAS COMPLETED

E ELECTRIC LOG OBTAINED

P TEST WELL CONVERTED TO PRODUCTION WELL

I HEREBY CERTIFY THAT I HAVE COMPLIED WITH ALL CONDITIONS STATED ON THE ABOVE-CAPTIONED "PERMIT TO DRILL WELL", AND THAT INFORMATION CONTAINED IN THIS REPORT IS TRUE, ACCURATE, AND COMPLETE TO THE BEST OF MY KNOWLEDGE, INFORMATION AND BELIEF.

DRILLERS NAME Joseph Mayne

(PLEASE PRINT) Joseph Mayne

SIGNATURE Joseph Mayne

DIAMETER OF SCREEN 3 1/2 (NEAREST INCH)

GRAVEL PACK

IF WELL DRILLED WAS A FLOWING WELL (CIRCLE BOX) YES NO

WRA USE ONLY (NOT TO BE FILLED IN BY DRILLER) (E.P.O.S.)

TELESCOPE CASING LOG INDICATOR OTHER DATA AVAILABLE

