

C 1 0348
SEQUENCE NO. (WRA USE ONLY)
(THIS NUMBER IS TO BE PUNCHED IN COLUMNS 3-8 ON ALL CARDS)

STATE OF MARYLAND
WATER RESOURCES ADMINISTRATION
TAWES STATE OFFICE BLDG., ANNAPOLIS, MD. 21401
WELL COMPLETION REPORT

THIS REPORT MUST BE SUBMITTED WITHIN 30 DAYS AFTER WELL COMPLETION
FILL IN THIS FORM COMPLETELY
COUNTY NUMBER

DATE RECEIVED (WRA USE ONLY) 7/31/78
DATE WELL COMPLETED 7/31/78
DEPTH OF WELL 200
(TO NEAREST FOOT) 20
PERMIT NO. FROM "PERMIT TO DRILL WELL" 410-77-464
DRILLER'S IDENTIFICATION NO. 42

OWNER DARDEN MARK
CITY NAME
STREET OR RFD 7820 BURTON CT.
POST OFFICE GREENBELT MD. 112

WELL DESCRIPTION

WELL LOG
STATE THE KIND OF FORMATIONS PENETRATED, THEIR COLOR, DEPTH, THICKNESS AND IF WATER BEARING

Table with columns: DESCRIPTION (USE ADDITIONAL SHEETS IF NECESSARY), FEET (FROM, TO), CHECK IF WATER BEARING. Includes handwritten notes like 'top soil' and 'sandstone'.

GROUTING RECORD

WELL HAS BEEN GROUTED (CIRCLE APPROPRIATE BOX) [Y]
TYPE OF GROUTING MATERIAL (CIRCLE BOX) CEMENT [CM] BENTONITE CLAY [BC]
NO. OF BAGS 14 NO. OF POUNDS 1400
GALLONS OF WATER 70
DEPTH OF GROUT SEAL (TO NEAREST FOOT) FROM 0 FT. TO 31 FT.

CASING RECORD

INSERT APPROPRIATE CODE BELOW
STEEL [ST] CONCRETE [CO]
PLASTIC [PL] OTHER [OT]
MAIN CASING TYPE [1] NOMINAL DIAMETER TOP (MAIN) CASING (NEAREST INCH) 60 TOTAL DEPTH OF MAIN CASING (NEAREST FOOT) 70

OTHER CASING (IF USED)

DIAMETER (INCH) FROM TO

SCREEN RECORD

INSERT APPROPRIATE CODE BELOW
STEEL [ST] BRASS OR BRONZE [BR] OPEN HOLE [HO]
PLASTIC [PL] OTHER [OT]
C 2
DEPTH (NEAREST WHOLE FOOT) FROM 1 TO 21
SLOTSIZE 1, 2, 3

PUMPING TEST

HOURS PUMPED (TO NEAREST HOUR) 0
PUMPING RATE (GALLONS PER MINUTE TO NEAREST GALLON) 15
METHOD USED TO MEASURE PUMPING RATE
WATER LEVEL (DISTANCE FROM LAND SURFACE) BEFORE PUMPING 17 (NEAREST FOOT) WHEN PUMPING 20 (NEAREST FOOT)
TYPE OF PUMPED USED (CIRCLE APPROPRIATE BOX) [A] AIR [P] PISTON [T] TURBINE [C] CENTRIFUGAL [R] ROTARY [O] OTHER [J] JET [S] SUBMERSIBLE

PUMP INSTALLED

TYPE OF PUMP (WRITE APPROPRIATE LETTER IN BOX - SEE ABOVE: A, C, J, P, R, S, T, O)
DRILLER WILL INSTALL PUMP (CIRCLE APPROPRIATE BOX) YES [Y] NO [N]
CAPACITY: GALLONS PER MINUTE (TO NEAREST GALLON) 31 35
PUMP HORSE POWER 37 41
PUMP COLUMN LENGTH (NEAREST FOOT) 43 47
CASING HEIGHT (CIRCLE APPROPRIATE BOX AND ENTER CASING HEIGHT) [+ ABOVE] LAND SURFACE [- BELOW] (NEAREST FOOT)

LOCATION OF WELL ON LOT

SHOW PERMANENT STRUCTURE SUCH AS BUILDINGS, SEPTIC TANKS, AND/OR OTHER LAND MARKS AND INDICATE NOT LESS THAN TWO DISTANCES (MEASUREMENTS TO WELL).

CIRCLE APPROPRIATE BOXES

- A WELL WAS ABANDONED AND SEALED WHEN THIS WELL WAS COMPLETED
E ELECTRIC LOG OBTAINED
P TEST WELL CONVERTED TO PRODUCTION WELL

I HEREBY CERTIFY THAT I HAVE COMPLIED WITH ALL CONDITIONS STATED ON THE ABOVE-CAPTIONED "PERMIT TO DRILL WELL", AND THAT INFORMATION CONTAINED IN THIS REPORT IS TRUE, ACCURATE, AND COMPLETE TO THE BEST OF MY KNOWLEDGE, INFORMATION AND BELIEF.

DRILLER'S NAME
SIGNATURE L.F. ...

DIAMETER OF SCREEN 58 (NEAREST INCH) FROM 58 TO 60
GRAVEL PACK
IF WELL DRILLED WAS A FLOWING WELL CIRCLE BOX [F]
WRA USE ONLY (NOT TO BE FILLED IN BY DRILLER) TELESCOPE CASING [70] LOG INDICATOR [72] OTHER DATA AVAILABLE [74, 75, 76]