

9538

SEQUENCE NO. (WRA USE ONLY)

STATE OF MARYLAND WATER RESOURCES ADMINISTRATION TAWES STATE OFFICE BLDG., ANNAPOLIS, MD. 21401 WELL COMPLETION REPORT

THIS REPORT MUST BE SUBMITTED WITHIN 30 DAYS AFTER WELL COMPLETION

FILL IN THIS FORM COMPLETELY

COUNTY NUMBER 20909

DATE RECEIVED (WRA USE ONLY)

DATE WELL COMPLETED 6/13/77

DEPTH OF WELL 145

PERMIT NO. FROM "PERMIT TO DRILL WELL" 40-713-2677

DRILLERS IDENTIFICATION NO. 209

OWNER: G. RAYSON FLOYD LAST NAME FIRST NAME

STREET OR RFD: 1541 LANG LOOK LAVE POST OFFICE: COLUMBIA MD 21043

WELL LOG STATE THE KIND OF FORMATIONS PENETRATED, THEIR COLOR, DEPTH, THICKNESS AND IF WATER BEARING

Table with columns: DESCRIPTION (USE ADDITIONAL SHEETS IF NECESSARY), FEET (FROM, TO), CHECK IF WATER BEARING. Includes handwritten notes: '32' open 10 bags C 12 gpm 14 June 77 OK ROM' and '36 145' x'.

GROUTING RECORD

WELL HAS BEEN GROUTED (CIRCLE APPROPRIATE BOX) YES [Y] NO [N]. TYPE OF GROUTING MATERIAL (CIRCLE BOX) CEMENT [CM] BENTONITE CLAY [BC]. NO. OF BAGS 10 NO. OF POUNDS 200. GALLONS OF WATER 90. DEPTH OF GROUT SEAL (TO NEAREST FOOT) FROM 0 FT. TO 54 FT.

CASING RECORD

INSERT APPROPRIATE CODE BELOW. STEEL [ST] CONCRETE [CO] PLASTIC [PL] OTHER [OT]. MAIN CASING TYPE [ST] NOMINAL DIAMETER TOP (MAIN) CASING (NEAREST INCH) 6. TOTAL DEPTH OF MAIN CASING (NEAREST FOOT) 36.

OTHER CASING (IF USED)

DIAMETER (INCH) FROM TO. Includes empty boxes for diameter and depth.

SCREEN RECORD

INSERT APPROPRIATE CODE BELOW. STEEL [ST] BRASS OR BRONZE [BR] OPEN HOLE [HO] PLASTIC [PL] OTHER [OT].

DEPTH (NEAREST WHOLE FOOT)

Table with columns 1-36 for depth measurements. Includes handwritten '145' at the end of the row.

DIAMETER OF SCREEN (NEAREST INCH)

FROM 56 TO 60.

GRAVEL PACK

IF WELL DRILLED WAS A FLOWING WELL CIRCLE BOX [F].

WRA USE ONLY (NOT TO BE FILLED IN BY DRILLER)

TELESCOPE CASING [] LOG INDICATOR [] OTHER DATA AVAILABLE []

PUMPING TEST

HOURS PUMPED (TO NEAREST HOUR) 6. PUMPING RATE (GALLONS PER MINUTE TO NEAREST GALLON) 12. METHOD USED TO MEASURE PUMPING RATE TIME.

WATER LEVEL (DISTANCE FROM LAND SURFACE)

BEFORE PUMPING 17. WHEN PUMPING 22. (NEAREST FOOT)

TYPE OF PUMP USED (CIRCLE APPROPRIATE BOX)

AIR [A] PISTON [P] TURBINE [T] CENTRIFUGAL [C] ROTARY [R] OTHER [O] JET [J] SUBMERSIBLE [S].

PUMP INSTALLED

TYPE OF PUMP (WRITE APPROPRIATE LETTER IN BOX - SEE ABOVE) [A]. DRILLER WILL INSTALL PUMP [Y]. CAPACITY: GALLONS PER MINUTE (TO NEAREST GALLON) 31. PUMP HORSE POWER 37. PUMP COLUMN LENGTH (NEAREST FOOT) 43.

CASING HEIGHT (CIRCLE APPROPRIATE BOX)

ABOVE [] BELOW [] LAND SURFACE (NEAREST FOOT) 2.

LOCATION OF WELL ON LOT

SHOW PERMANENT STRUCTURE SUCH AS BUILDINGS, SEPTIC TANKS, AND/OR OTHER LAND MARKS AND INDICATE NOT LESS THAN TWO DISTANCES (MEASUREMENTS TO WELL).

CIRCLE APPROPRIATE BOXES

[A] A WELL WAS ABANDONED AND SEALED WHEN THIS WELL WAS COMPLETED. [E] ELECTRIC LOG OBTAINED. [P] TEST WELL CONVERTED TO PRODUCTION WELL.

I HEREBY CERTIFY THAT I HAVE COMPLIED WITH ALL CONDITIONS STATED ON THE ABOVE-CAPTIONED "PERMIT TO DRILL WELL", AND THAT INFORMATION CONTAINED IN THIS REPORT IS TRUE, ACCURATE, AND COMPLETE TO THE BEST OF MY KNOWLEDGE, INFORMATION AND BELIEF.

DRILLERS NAME: Howard Dillen

(PLEASE PRINT) Howard Dillen

SIGNATURE: Howard Dillen