
 WATER WELL ABANDONMENT-SEALING REPORT FORM

SUBMIT COPIES OF COMPLETED FORM TO:

- * COUNTY ENVIRONMENTAL AGENCY (contact MDE, WMA if address needed)
- * WELL OWNER
- * MDE, WATER MANAGEMENT ADMINISTRATION, WELL PROGRAM

DATE WELL ABANDONED: 9-3-15 (month/day/year)

* PERMIT NUMBER OF ABANDONED WELL (if any) _____


* PERMIT NUMBER OF REPLACEMENT WELL: _____

* PERSON ABANDONING WELL: Allen Bryant WELL DRILLER'S LICENSE NUMBER: 109

* OWNER'S NAME: Carrigan Homes CIRCLE: MWD / MSD / MGD

* WELL LOCATION:
 COUNTY: Howard
 NEAREST TOWN: Ellicott City
 TAX MAP 0024 BLOCK _____ PARCEL _____
 SUBDIVISION: _____
 SECTION: _____ LOT: _____
 STREET ADDRESS: 3609 Mac Alpine Rd

SITE LOCATION MAP



LATITUDE 3 9.2714043

LONGITUDE 7 6.8298950

LOG OF SEALING MATERIAL

MATERIAL	FEET	
	FROM	TO
<u>Cement</u>	<u>-5</u>	<u>70</u>
VOLUME OF MATERIAL USED		
<u>1 yard</u>		

* TYPE OF WELL BEING ABANDONED:
 DRILLED JETTED
 BORED HAND DUG
 OTHER (specify) _____

* USE CODE:
 DOMESTIC MUNICIPAL/PUBLIC
 IRRIGATION INDUSTRIAL
 TEST/OBSERVATION GEOTHERMAL

* TYPE OF CASING:
 STEEL PLASTIC
 CONCRETE OTHER (specify) _____

SIZE OF CASING: 6 INCHES IN DIAMETER

DEPTH OF WELL: 70 FEET DEEP

WAS ANY CASING REMOVED? YES NO
 If yes, length removed, in feet: _____

WAS CASING RIPPED OR PERFORATED? YES NO

SIGNATURE-MASTER WELL DRILLER OR SUPERVISING SANITARIAN LICENSE# 009

CIRCLE ONE MWD / MSD / MGS DATE 9-18-15

Pursuant to § 10-624 of the State Govt. Article of the Maryland Code, personal info requested on this form is used in processing this form pursuant to COMAR 26.04.04. Failure to provide the info may result in this form not being processed. You have the right to inspect, amend, or correct this form. The Maryland Department of the Environment is subject to the Maryland Public Information Act. This form may be made available on the Internet via MDE's website and is subject to inspection or copying, in whole or in part, by the public and other governmental agencies, if not protected by federal or State Law.

Wolf, Kevin

From: Wolf, Kevin
Sent: Wednesday, October 07, 2015 1:47 PM
To: theresa@foglesinc.com
Cc: Bricker, Robert
Subject: 3605 McAlpine Road well abandonment
Attachments: 20151007_133640_resized_1.jpg

Theresa,

Please be informed, pit wells of this nature must have the 'pit' completely removed. A properly sealed well should terminate to the top of the casing. Unfortunately, I could not see the top of the well casing here for this pit well due to all the debris and trash (i.e. hence removal of the pit). Is there a way you remove this so we can see the top of the casing? I tried myself as did Robert to remove some of the debris but was unsuccessful.

Thanks

Kevin



SDP-15-070; MacAlpine

Sheet 1

Place Health Officer's signature block on SHEET 1 and conditioned 'APPROVED; FOR PUBLIC WATER AND PUBLIC SEWERAGE SYSTEMS'.

Comment: There is a drilled well on Lot 30, in the pit identified on this plan as "WELL HOUSE RUIN". This well must be sealed by a Licensed Well Driller, and the Well Abandonment Report received by the Health Department, prior to the Approving Authority signing this plan.

SITE INSPECTION SHEET

OWNER: _____ PHONE #: _____


ADDRESS: 3609 Mac Alpine CONTRACTOR: _____

WELL TAG #: _____

SUBDIVISION: _____ LOT: _____ COUNTY #: _____

PROPOSAL: SDP-15-070; well must be sealed for Health Dept. approval

LOCATION DIAGRAM



COMMENTS: Pit well; no evidence that it has been sealed; plumbing in pit appears to be intact, though partly covered with debris.

Discharge location of former septic system not found.

DATE: 6/22/2015

INSPECTOR: R Bricker

Williams, Jeffrey

From: John Carney <jcarney@bei-civilengineering.com>
Sent: Thursday, October 22, 2015 3:41 PM
To: Williams, Jeffrey
Subject: RE: SDP-15-070, MacAlpine

Jeff, that is fine. Sorry we didn't correct it prior to submitting. John

From: Williams, Jeffrey [<mailto:jewilliams@howardcountymd.gov>]
Sent: Thursday, October 22, 2015 3:13 PM
To: John Carney (jcarney@bei-civilengineering.com)
Subject: SDP-15-070, MacAlpine

We have SDP-15-070 for signature and I want to get your confirmation for us to line out comment 14 on the cover page. It states that the existing well must be abandoned. Since that's already been done, the note no longer applies. Let me know if that's ok and we'll line it out and sign the plan. Thanks

Jeff Williams
Program Supervisor, Well & Septic Program
Bureau of Environmental Health
Howard County Health Dept.
410-313-4261
jewilliams@howardcountymd.gov

CONFIDENTIALITY NOTICE

This message and the accompanying documents are intended only for the use of the individual or entity to which they are addressed and may contain information that is privileged, confidential, or exempt from disclosure under applicable law. If the reader of this email is not the intended recipient, you are hereby notified that you are strictly prohibited from reading, disseminating, distributing, or copying this communication. If you have received this email in error, please notify the sender immediately and destroy the original transmission.