

PUB. SEWER STATUS VERIFIED BY _____

ISSUE DATE: _____

PERMIT

P 536035

APPROVAL DATE: 12/19/2011

A REPAIR

Septic Repair ON-SITE SEWAGE DISPOSAL SYSTEM HOWARD COUNTY HEALTH DEPARTMENT BUREAU OF ENVIRONMENTAL HEALTH

William Hopkins IS PERMITTED TO INSTALL ALTER

ADDRESS: 17540 Old Frederick Road PHONE NUMBER: 301-829-1166

SUBDIVISION: _____ LOT NUMBER: _____

ADDRESS: 759 Long Corner Road PROPERTY OWNER: Kenneth Lee Haines

SEPTIC TANK CAPACITY (GALLONS): N/A

PUMP CHAMBER CAPACITY (GALLONS): _____

NUMBER OF BEDROOMS: _____

SQUARE FEET OF HOUSE: _____

LINEAR FEET OF TRENCH REQUIRED: _____

TRENCHES:	
LOCATION:	
PURPOSE:	

PLANS APPROVED: _____ DATE: _____

- NOTE: PERMIT VOID AFTER 2 YEARS
- NOTE: CONTRACTOR RESPONSIBLE FOR SCHEDULING A PRE-CONSTRUCTION INSPECTION FOR ALL INSTALLATIONS
- NOTE: WATERTIGHT SEPTIC TANKS REQUIRED
- NOTE: ALL PARTS OF SEPTIC SYSTEM SHALL BE 100 FEET FROM ANY WATER WELL
- NOTE: MANHOLE RISERS REQUIRED ON ALL SEPTIC TANKS AND PUMP CHAMBERS

NEITHER THE HOWARD COUNTY COUNCIL OR THE HEALTH DEPARTMENT IS RESPONSIBLE FOR THE SUCCESSFUL OPERATION OF ANY SYSTEM PERMITTEE RESPONSIBLE FOR OBTAINING FINAL APPROVAL ON THIS PERMIT CALL 410-313-1771 FOR INSPECTION OF SEPTIC SYSTEM

NOT TO SCALE

TRENCH/DRAINFIELD DATA

WIDTH 3' INLET 5' BOTTOM 6'

NUMBER OF TRENCHES 2

TOTAL LENGTH 201'

ABSORPTION AREA 60.3

DISTRIBUTION BOX LEVEL Levelers

DISTRIBUTION BOX BAFFLE Yes

DISTRIBUTION BOX PORT Yes

See As-Built Drawing
On Separate Sheet

SEPTIC TANK DATA

SEPTIC TANK 1 LEVEL _____

MANUFACTURER Concrete

CAPACITY _____ GAL

SEAM LOC _____

TANK LID DEPTH 1'

BAFFLES _____

BAFFLE FILTER _____

MANHOLE LOC None

6" PORT LOC Front

WATERTIGHT TEST _____

SLOTTED _____

DATE ON LID _____

PUMP/SEPTIC TANK LEVEL N/A

MANUFACTURER _____

CAPACITY _____ GAL

SEAM LOC _____

TANK LID DEPTH _____

BAFFLES _____

BAFFLE FILTER _____

MANHOLE LOC _____

6" PORT LOC _____

WATERTIGHT TEST _____

SLOTTED _____

DATE ON LID _____

ROAD NAME

PRE-CONSTRUCTION:

12/2/2011 I install two 100' trenches from garage heading northward on contour, O.K. to connect a distribution box to the drywell. Drywell must be pumped out and filled with gravel. BB

INSTALLATION:

12/19/2011 No follow-ups called in. System finished. O.K. to backfill. Drywell filled with gravel. BB

FINAL INSPECTOR B. Baker DATE OF APPROVAL 12/19/2011

