



# HERITAGE Land Development

---

LAND PLANNING ♦ DEVELOPMENT ♦ MARKETING ♦ ZONING ♦ VALUATION

---

## MEMORANDUM

---

**TO:** Steve Krieg  
**FROM:** Tim Feaga  
**DATE:** May 2, 2003  
**SUBJECT:** Carroll Property

---

Steve,

Attached is the well test indicating potable water for Mr. Carroll's well. As you may recall, he would like to use the existing well for a new tenant home. As I gathered from your group, this would be allowed if the water was potable and the capacity was sufficient. While Stephanie could not find the well completion report, she did find the well to have yielded 25 gallons per minute, along with some decent depths.

Should this be of any concern, please feel free to contact me; otherwise, thank you for your help in this matter. I believe the building permit may be submitted as early as next week.

Sincerely,

Tim Feaga

cc: Philip Carroll

# CASELL TESTING, INC.

ENVIRONMENTAL SAMPLING AND TESTING

10940 BEAVER DAM ROAD, HUNT VALLEY, MD 21030-2211

(410) 252-7742

Andes Pest Control  
1707 Reisterstown Road  
Pikesville, Maryland 21208

Report Date: April 18, 2003

CTI NUMBER: 03-1535

This information was provided by Andes Pest Control:

Sampler: 6701DA  
Date/Time Sampled: 04/17/03 at 8:12  
Well Info: Not Provided

Job location: Carroll  
3500 Manor Lane  
Ellicott City, MD 21042

Listed below are the results that were determined on the water sample collected and delivered by Andes Pest Control:

-----  
RESULTS:

Nitrate-N:	<1.0 mg/L	Pass
Turbidity:	5.0 NTU	Pass
Coliform Bacteria:	ABSENT	Pass



Heather R. Beam  
Cassell Testing, Inc.

Cassell Testing, Inc. is not responsible for the collection or transportation of the sample.



# HERITAGE Land Development

---

LAND PLANNING ♦ DEVELOPMENT ♦ MARKETING ♦ ZONING ♦ VALUATION

---

## MEMORANDUM

---

**TO:** Steve Krieg  
**FROM:** Tim Feaga  
**DATE:** May 2, 2003  
**SUBJECT:** Carroll Property

---

Steve,

Attached is the well test indicating potable water for Mr. Carroll's well. As you may recall, he would like to use the existing well for a new tenant home. As I gathered from your group, this would be allowed if the water was potable and the capacity was sufficient. While Stephanie could not find the well completion report, she did find the well to have yielded 25 gallons per minute, along with some decent depths.

Should this be of any concern, please feel free to contact me; otherwise, thank you for your help in this matter. I believe the building permit may be submitted as early as next week.

Sincerely,

Tim Feaga

cc: Philip Carroll