

1/24/95
10:00

APPLICATION

PERCOLATION TESTING

A 50485
P _____

HOWARD COUNTY HEALTH DEPARTMENT
BUREAU OF ENVIRONMENTAL HEALTH
P.O. BOX 476 ELLICOTT CITY, MARYLAND 21043
TELEPHONE. 461-9933

PERCOLATION OK
EXISTING LOT
CLW

DISTRICT _____
DATE 4/18/95

TO: THE COUNTY HEALTH OFFICER
ELLICOTT CITY, MARYLAND

I, HEREBY, APPLY FOR THE NECESSARY TEST IN ORDER TO CONSTRUCT (OR RECONSTRUCT) A SEWAGE DISPOSAL SYSTEM.

PROPERTY OWNER Allen Grimes Patricia Olen

ADDRESS 4720 Linthicum Rd. Dayton MD 21036 PHONE 531-3603

PROSPECTIVE BUYER _____
ADDRESS _____ PHONE _____

PROPERTY LOCATION:
SUBDIVISION N/A LOT NO N/A

ROAD AND DESCRIPTION Howard Rd. 4730 Linthicum Road

TAX MAP 28 PARCEL # 118
SIZE OF LOT 2.07 acres TYPE BLDG Single Family
(SINGLE FAMILY DWELLING OR COMMERCIAL)

BLDG. PERMIT SIGNED
AND RETURNED 4/18/95
Serial # 58953-SFP-3Bm

THE SYSTEM INSTALLED UNDER THIS APPLICATION IS ACCEPTABLE ONLY UNTIL PUBLIC FACILITIES BECOME AVAILABLE. I FULLY UNDERSTAND THE FEE CONNECTED WITH THE FILING OF THIS PERC TEST APPLICATION IS NON-REFUNDABLE UNDER ANY CIRCUMSTANCES. I ALSO AGREE TO COMPLY WITH ALL M.O.S.H.A. REQUIREMENTS IN TESTING THIS LOT.

Shelley D. Rockwell
(SIGNATURE OF APPLICANT)

APPROVED BY _____ FOR _____ DATE _____

REJECTED BY _____ FOR _____ DATE _____

HOLD PENDING FURTHER TESTS PERC OK DATE 1/24/95

REASONS FOR REJECTION OR HOLDING PERC OK, HOLD FOR PLAT

HD-216

THIS IS NOT A PERMIT



HOWARD COUNTY HEALTH DEPARTMENT

Joyce M. Boyd, M.D., County Health Officer

March 16, 1995

Mr. Gary Barnard
1612 Brittle Branch Way
Woodbine, MD 21797

RE: Percolation Certification Plat
Alton Grimes Property
Map 28, Parcel 118
Linthicum Road

Dear Mr. Barnard,

The above referenced document has been signed by the Howard County Health Officer.

The document was recommended for signature subject to the following caution: the location of the proposed well site is the subject of some concern due to its land position downslope of existing septic systems (and their likely repair areas) serving properties across Linthicum Road. While the 100-foot minimum setback from this proposed well location to all septic systems/repair areas has been maintained, the concern is that a well drilled at this location may be somewhat more vulnerable to contamination due to its land position and the location of the swale and the swale's tendency to concentrate pollutants.

However, there does not appear to be a clearly better solution to this situation, and the risk of contamination is by no means certain. Therefore, the decision was made by this office to accept the plan for signature as long as all parties are aware of the concerns regarding the proposed well site.

Very truly yours,

Mark E. Rifkin, R.S.
Sanitarian
Water & Sewerage Program

MR
cc: Mr. Alton Grimes