

153  
 1' brn L, msbk  
 1.5' brn col 2' sbk  
 yel-brn, red-brn  
 dk grey-brn  
 2' thick platy many mica  
 yel-red & yel-brn  
 sl, thick platy many mica  
 4.2' yel-brn chls thick platy many coarse mica  
 11'

156  
 1' brn L 2' sbk to 2msbk  
 1.8' dk brn, red-brn & yel-brn ls, thin platy many coarse mica  
 3.2' yel-red & yel-brn ls thick platy few thin layers of grey ls, ss  
 13'

155  
 22' dk brn L, 2' sbk, brn L, 2msbk, brn sl, 1msbk  
 yel-red sl, dk brn, grey-brn & yel-brn sl  
 thin platy, very moist  
 4.5' yel-red sl, alternating layers R B sticker  
 dk-brn & yel-brn ls, thick platy  
 8' yel-red ls, thin platy  
 yel-brn chls, thick platy common coarse mica 14'



154  
 0.5' dk brn sl, 1/2 yel-brn sl, 7' sbk com mica  
 2' brn to brn-yel sl, 2' sbk many mica  
 2' yel-red sl, thick platy many mica  
 1' yel-red & yel-brn sl, thin platy many coarse mica  
 4' yel-brn, yel-red & pale brn ls, thin platy many coarse mica  
 14'

152  
 1.2' dk brn sl, yel-red sl, 2' sbk com mica  
 red-yel & yel-brn ls, thick platy many mica  
 2.2' red-yel & lt. yel-brn ls, thin platy many mica  
 4' yel-brn chls thin platy many coarse mica  
 13'

DATE	TEST #	DEPTH	START	BREAK 1" DROP	STOP 2" DROP	TIME OF 2ND INCH	P/F/H
3/18/15	153	3.3' / 11'	3:18	3:21	3:26	5	P
3/18/15	156	4.3' / 13'	3:29	3:31	3:34	3	P
3/18/15	155	6.3' / 14'	3:58	4:00	4:04	4	P
3/19/15	154	4.0' / 14'	9:52	9:54	9:57	3	P
3/19/15	152	5.7' / 13'	10:20	10:21:40	10:23:40	2	P

REMARKS Limit Trench Bottom

SANITARIAN R B sticker BACKHOE Hatfield OTHERS Art Leonard

TEST HOLES USED IN SDA Donnie AVG. PERC TIME \_\_\_\_\_ SQ. FT/BR \_\_\_\_\_

TRENCH WIDTH \_\_\_\_\_ INLET DEPTH \_\_\_\_\_ MAX. BOT DEPTH \_\_\_\_\_ EFFECTIVE SW \_\_\_\_\_