
Maura J. Rossman, M.D., Health Officer

MEMORANDUM

Sent via email to:

Anthony.berarducci@gmail.com

TO: Anthony Berarducci

FROM: Kevin M. Wolf, LEHS, REHS/RS,
Supervisor Groundwater Mgmt. Sec.
Well & Septic Program

Kmw

DATE: June 15, 2022

RE: 2730 Jennings Chapel Road
Woodbine, MD 21797
M. 13 P. 109 40.16AC
(Demolition of existing house, rebuild new sfd)

This is to advise that the Howard County Health Department recommends issuance of the demolition permit for the above referenced property.

The existing septic system (tank and trenches) has been properly located, pumped and collapsed. This task was completed by Fogle's Septic on May 25th, 2022 respectively. Confirmation has been received by this department.

The existing drilled well (tag unknown) was property located and sealed by Wesley Wolfe (MWD 598) on May 26th, 2022. The MDE well abandonment report was received by our office and reviewed for compliance.

Future plans to rebuild on the subject property may require a percolation certification plan per Howard County regulations.

IF ANY WELL OR SEPTIC COMPONENTS ARE FOUND DURING SITE WORK, YOU MUST NOTIFY THIS OFFICE IMMEDIATELY!!

KMW

Cc: File

WATER WELL ABANDONMENT-SEALING REPORT FORM

SUBMIT COPIES OF COMPLETED FORM TO:

- * COUNTY ENVIRONMENTAL AGENCY (contact MDE, WMA if address needed)
- * WELL OWNER
- * MDE, WATER MANAGEMENT ADMINISTRATION, WELL PROGRAM

DATE WELL ABANDONED: 5/26/22 (month/day/year)

* PERMIT NUMBER OF ABANDONED WELL (if any) NA


* PERMIT NUMBER OF REPLACEMENT WELL: none issued yet

* PERSON ABANDONING WELL: Wesley Wolfe WELL DRILLER'S LICENSE NUMBER: MWD 598
 CIRCLE MWD / MSD / MGD

* OWNER'S NAME: ORNL LLC

* WELL LOCATION:
 COUNTY: Haward
 NEAREST TOWN: Woodbine
 TAX MAP 0013 BLOCK PARCEL 0109
 SUBDIVISION: 1003
 SECTION: PAR 1
 STREET ADDRESS: 2730 Jennings Chapel Rd

SITE LOCATION MAP



LATITUDE 39.291139

LONGITUDE 77.102573

LOG OF SEALING MATERIAL

MATERIAL	FEET	
	FROM	TO
Benotite	120	3
Portland	3	Ø
VOLUME OF MATERIAL USED		
<u>Benotite (28 Bbls) Portland (1 cement)</u>		

* TYPE OF WELL BEING ABANDONED:
 DRILLED JETTED
 BORED HAND DUG
 OTHER (specify) _____

* USE CODE:
 DOMESTIC MUNICIPAL/PUBLIC
 IRRIGATION INDUSTRIAL
 TEST/OBSERVATION GEOTHERMAL

* TYPE OF CASING:
 STEEL PLASTIC
 CONCRETE OTHER (specify) _____

SIZE OF CASING: 6 INCHES IN DIAMETER

DEPTH OF WELL: 120 FEET DEEP

WAS ANY CASING REMOVED? YES NO
 If yes, length removed, in feet: _____

WAS CASING RIPPED OR PERFORATED? YES NO

SIGNATURE-MASTER WELL DRILLER OR SUPERVISING SANITARIAN Wesley A. Way LICENSE# MWD 598 CIRCLE ONE MWD / MSD / MGS DATE 5/26/22

Pursuant to § 10-624 of the State Govt. Article of the Maryland Code, personal info requested on this form is used in processing this form pursuant to COMAR 26.04.04. Failure to provide the info may result in this form not being processed. You have the right to inspect, amend, or correct this form. The Maryland Department of the Environment is subject to the Maryland Public Information Act. This form may be made available on the Internet via MDE's website and is subject to inspection or copying, in whole or in part, by the public and other governmental agencies, if not protected by federal or State Law.

Fogle's Septic Clean Inc.

Fogle's Portable Toilets • Fogle's Well Drilling LLC • Fogle's Excavating, LLC



May 26, 2022

Howard Co Dept of Environmental Health
8930 Stanford Blvd
Columbia, Md 21045


To Whom it may concern,

On May 25th 2022 Fogle's Septic Clean Inc, has abandoned the septic tank located at 2730 Jennings Chapel Rd in Woodbine for Chris Beraducci. The empty tank was crushed and filled in with fill dirt. A drawing is attached
If you have any questions please call me at the office 410-795-5670.

Sincerely,

A handwritten signature in cursive script that reads "Kurt Cassell".

Kurt Cassell
Fogle's Septic Clean, Inc.



Septic Tank
 Abandonment on
 5/25/22
 by Fogle's Septic