

October 15, 2021

Mr. Hank Oswald, L.E.H.S.  
Howard County Health Department  
Well & Septic Program

Mr. Oswald,

Please accept this letter as our request for an exception to the 20' setback from our existing well to our pool. We are requesting that the setback be reduced to 7'. The existing well has been in place since the 70's and was discontinued for use sometime in the 80's or 90's. In 2015 we worked with your office to bring the well back online for the outside hose bibs for the purpose of watering our lawn and gardens. We would like to continue to use the well for those purposes as well as for outdoor cleaning. We spoke with a well contractor about relocating the well and that option was cost prohibitive. For our in-home use we are connected to the county's water supply. Please let us know if we can provide any further information for your consideration.

Thanks,




Matthew & Anna Young  
10746 Judy Ln.  
Columbia, MD 21044

10/27/21

Approved







## Williams, Jeffrey

---

**From:** Matthew Young <mattyoungarl@gmail.com>  
**Sent:** Monday, October 25, 2021 2:14 PM  
**To:** Williams, Jeffrey  
**Subject:** Re: 10746 Judy Lane Health Dept waiver

[Note: This email originated from outside of the organization. Please only click on links or attachments if you know the sender.]

Mr. Jeffery, thank you for your quick response. The well pump is still in the well, however the expansion tank was removed from inside of the house. I will contact our plumber today to request to have the expansion tank replaced and the hose bib reconnected to the well and also the 8" above grade extension installed. I can then give you a timeliness for when that work can be completed.

Thanks,  
Matt

On Mon, Oct 25, 2021, 10:08 AM Williams, Jeffrey <[jewilliams@howardcountymd.gov](mailto:jewilliams@howardcountymd.gov)> wrote:

Hello Mr. Young. I am reviewing your waiver request for the well setback to a pool. I see from our notes that you indicated there is no pump in the well? We cannot consider a waiver if the well is not in service. Do you intend to have a new pump installed and have the well connected to an outside hosebib with no cross connection to the interior plumbing? The other item I noticed from the pictures is that the well head is no longer at least 8 inches above grade as required by regulation. We can review this condition once I hear back from you on whether your intention is to install a new pump in the well. Thanks

Jeff Williams

Deputy Director

Bureau of Environmental Health

Howard County Health Dept.

410-313-4261

[jewilliams@howardcountymd.gov](mailto:jewilliams@howardcountymd.gov)


### CONFIDENTIALITY NOTICE

This message and the accompanying documents are intended only for the use of the individual or entity to which they are addressed and may contain information that is privileged, confidential, or exempt from disclosure under applicable law. If the reader of this email is not the intended recipient, you are hereby notified that you are strictly prohibited from reading, disseminating, distributing, or copying this communication. If you have received this email in error, please notify the sender immediately and destroy the original transmission.

SITE INSPECTION SHEET

OWNER: Anna E Matthew Young PHONE #: \_\_\_\_\_  
ADDRESS: 10746 Judy Lane CONTRACTOR: \_\_\_\_\_  
Columbia, MD 21044 WELL TAG #: public  
SUBDIVISION: \_\_\_\_\_ LOT: \_\_\_\_\_ COUNTY #: \_\_\_\_\_  
PROPOSAL: keep existing well for irrigation only.

LOCATION DIAGRAM



COMMENTS: Well located 7' from pool waters edge &  
beneath pool deck tile.

DATE: 10/14/21 INSPECTOR: Hank Oswald

## Williams, Jeffrey

---

**From:** Matthew Young <mattyoungarl@gmail.com>  
**Sent:** Wednesday, October 27, 2021 3:13 PM  
**To:** Williams, Jeffrey  
**Subject:** Re: 10746 Judy Lane Health Dept waiver

[Note: This email originated from outside of the organization. Please only click on links or attachments if you know the sender.]

That's great news. Thank you such much for your help through this process. I will be back in touch shortly.

Thanks,  
Matt

On Wed, Oct 27, 2021, 3:09 PM Williams, Jeffrey <[jewilliams@howardcountymd.gov](mailto:jewilliams@howardcountymd.gov)> wrote:

Hello Mr. Young. We did review your waiver request and we are willing to approve the well if it is put in service and the casing extended to at least 8 inches above grade. So, you can begin that process. Let me know when it is complete and we will be able to sign off on the waiver and the pool permit at that time. Thanks

Jeff

**From:** Williams, Jeffrey  
**Sent:** Monday, October 25, 2021 2:19 PM  
**To:** Matthew Young <[mattyoungarl@gmail.com](mailto:mattyoungarl@gmail.com)>  
**Subject:** RE: 10746 Judy Lane Health Dept waiver

Before you talk to anyone about doing any work, wait until you hear from us regarding a decision on the waiver request. I need to have our director review the request. But, I first wanted to get all the details of the existing condition. We will get back to you with an answer on whether the waiver was approved and what any conditions of the waiver might be. Let me know if there are questions. Thanks

Jeff

**From:** Matthew Young <[mattyoungarl@gmail.com](mailto:mattyoungarl@gmail.com)>  
**Sent:** Monday, October 25, 2021 2:14 PM  
**To:** Williams, Jeffrey <[jewilliams@howardcountymd.gov](mailto:jewilliams@howardcountymd.gov)>  
**Subject:** Re: 10746 Judy Lane Health Dept waiver

[Note: This email originated from outside of the organization. Please only click on links or attachments if you know the sender.]

Mr. Jeffery, thank you for your quick response. The well pump is still in the well, however the expansion tank was removed from inside of the house. I will contact our plumber today to request to have the expansion tank replaced and the hose bib reconnected to the well and also the 8" above grade extension installed. I can then give you a timeliness for when that work can be completed.

Thanks,

Matt

On Mon, Oct 25, 2021, 10:08 AM Williams, Jeffrey <[jewilliams@howardcountymd.gov](mailto:jewilliams@howardcountymd.gov)> wrote:

Hello Mr. Young. I am reviewing your waiver request for the well setback to a pool. I see from our notes that you indicated there is no pump in the well? We cannot consider a waiver if the well is not in service. Do you intend to have a new pump installed and have the well connected to an outside hosebib with no cross connection to the interior plumbing? The other item I noticed from the pictures is that the well head is no longer at least 8 inches above grade as required by regulation. We can review this condition once I hear back from you on whether your intention is to install a new pump in the well. Thanks

Jeff Williams

Deputy Director

Bureau of Environmental Health

Howard County Health Dept.

410-313-4261

[jewilliams@howardcountymd.gov](mailto:jewilliams@howardcountymd.gov)

#### CONFIDENTIALITY NOTICE

**This message and the accompanying documents are intended only for the use of the individual or entity to which they are addressed and may contain information that is privileged, confidential, or exempt from disclosure under applicable law. If the reader of this email is not the intended recipient, you are hereby notified that you are strictly prohibited from reading, disseminating, distributing, or copying this communication. If you have received this email in error, please notify the sender immediately and destroy the original transmission.**

## Williams, Jeffrey

---

**From:** Williams, Jeffrey  
**Sent:** Wednesday, October 6, 2021 3:42 PM  
**To:** Blotzer, William; Anest, Cathy  
**Cc:** Wood, Joe; Oswald, Hank  
**Subject:** RE: 10746 Judy Ln B20004420

Hi Bill. We tried to get the homeowner to revise the plot plan and set up a site visit way back in March, but we never heard from them until just now after you guys adhered to our condition, so thanks for that. The system worked. We're now working with them because they claim the well was sealed, but we do not have a record of that. We're contacting the driller and will probably do a site visit. We'll let you know the outcome. Thanks

Jeff Williams  
Deputy Director  
Bureau of Environmental Health  
Howard County Health Dept.  
410-313-4261  
[jewilliams@howardcountymd.gov](mailto:jewilliams@howardcountymd.gov)

### CONFIDENTIALITY NOTICE

This message and the accompanying documents are intended only for the use of the individual or entity to which they are addressed and may contain information that is privileged, confidential, or exempt from disclosure under applicable law. If the reader of this email is not the intended recipient, you are hereby notified that you are strictly prohibited from reading, disseminating, distributing, or copying this communication. If you have received this email in error, please notify the sender immediately and destroy the original transmission.

**From:** Blotzer, William <[wblotzer@howardcountymd.gov](mailto:wblotzer@howardcountymd.gov)>  
**Sent:** Friday, October 1, 2021 8:48 AM  
**To:** Williams, Jeffrey <[jewilliams@howardcountymd.gov](mailto:jewilliams@howardcountymd.gov)>; Anest, Cathy <[canest@howardcountymd.gov](mailto:canest@howardcountymd.gov)>  
**Cc:** Wood, Joe <[jowood@howardcountymd.gov](mailto:jowood@howardcountymd.gov)>  
**Subject:** 10746 Judy Ln B20004420

Jeff, we have a Health Dept. hold on the Subject pool permit, can this be removed? The septic is in the front of the property and the pool and deck are located in the rear.

Bill Blotzer  
Supervisor – Building/Fire Protection Inspections  
Howard County Inspection & Enforcement, DILP  
7125 Riverwood Dr., Suite D2, Columbia, MD 21046  
[wblotzer@howardcounty.gov](mailto:wblotzer@howardcounty.gov)  
410-313-1811

## Williams, Jeffrey

---

**From:** Anest, Cathy  
**Sent:** Thursday, March 18, 2021 11:22 AM  
**To:** Williams, Jeffrey  
**Cc:** Oswald, Hank; Blotzer, William  
**Subject:** RE: B20004420 10746 Judy Ln

Jeff,  
I placed a 'hold' on the permit so inspections cannot be scheduled. But, I am copying Bill Blotzer, Chief Building Inspector on this email as well to make that Division aware.  
As soon as you find out if the setback is okay, please let me know and I will lift the condition.  
Thanks.  
Cathy

**From:** Williams, Jeffrey <jewilliams@howardcountymd.gov>  
**Sent:** Thursday, March 18, 2021 8:35 AM  
**To:** Anest, Cathy <canest@howardcountymd.gov>  
**Cc:** Oswald, Hank <hoswald@howardcountymd.gov>  
**Subject:** B20004420 10746 Judy Ln

Hi Cathy. I approved this BP without realizing that they still had their old well in service as an irrigation well. They did not show it on a plot plan and the pool may be pretty close to it. I saw that the permit was mailed to the applicant yesterday. We are getting in contact with them to tell them we need to check the setback, but is there any way to put that permit on hold until we can confirm the well isn't too close to the proposed pool?

Jeff Williams  
Program Supervisor, Well & Septic Program  
Bureau of Environmental Health  
Howard County Health Dept.  
410-313-4261  
[jewilliams@howardcountymd.gov](mailto:jewilliams@howardcountymd.gov)

### CONFIDENTIALITY NOTICE

**This message and the accompanying documents are intended only for the use of the individual or entity to which they are addressed and may contain information that is privileged, confidential, or exempt from disclosure under applicable law. If the reader of this email is not the intended recipient, you are hereby notified that you are strictly prohibited from reading, disseminating, distributing, or copying this communication. If you have received this email in error, please notify the sender immediately and destroy the original transmission.**

## Oswald, Hank

---

**From:** Oswald, Hank  
**Sent:** Thursday, March 18, 2021 8:41 AM  
**To:** 'MATTYOUNGARL@GMAIL.COM'  
**Subject:** B20004420\_10746 Judy Lane\_Pool

Hello Mr. Young:

Good morning. Our office approved your building permit for a pool not realizing that you have an irrigation well on the property. The setback from a well to the pool waters edge is 20 feet. We would like to confirm this setback distance is being met by having you stake out the pool and conducting a site visit.

Should you have any questions, or wish to discuss, please don't hesitate to contact me.

Thanks,

Hank

Hank Oswald, L.E.H.S.  
Howard County Health Department  
Bureau of Environmental Health  
Well & Septic Program  
8930 Stanford Boulevard  
Columbia, MD 21045  
(410) 313 - 1786  
hoswald@howardcountymd.gov

## Hill, Amanda

---

**From:** Matt Young <matt@revolutionsolar.energy>  
**Sent:** Monday, December 14, 2020 1:11 PM  
**To:** Hill, Amanda; Whalen, Debbie  
**Subject:** RE: 10746 Judy Lane

[Note: This email originated from outside of the organization. Please only click on links or attachments if you know the sender.]

Thanks so much Amanda.

**SFD/ CONSTRUCTION 7.5' X 24' OPEN DECK, 0 STEPS & INSTALL 16' X 38' INGROUND SWIMMING POOL, DEPTH 3'-6" – 5'-10" , WITH FENCE TO CODE**

**From:** Hill, Amanda <ahill@howardcountymd.gov>  
**Sent:** Monday, December 14, 2020 12:32 PM  
**To:** Matt Young <matt@revolutionsolar.energy>; Whalen, Debbie <dwhalen@howardcountymd.gov>  
**Subject:** RE: 10746 Judy Lane

Matt,

We can use this email to update your description of work, however, please provide us with the dimensions of the open deck as well as the dimensions of the in-ground pool and depth:

**SFD/ CONSTRUCTION \_\_\_ X \_\_\_ OPEN DECK, \_\_\_ STEPS & INSTALL \_\_\_ X \_\_\_ INGROUND SWIMMING POOL, DEPTH \_\_\_ - \_\_\_ , WITH FENCE TO CODE**

Thank you for your prompt response,

*Amanda Hill*

Regulation Support Technician II  
Department of Inspections, Licenses and Permits  
3430 Court House Drive  
Ellicott City, MD 21043  
[ahill@howardcountymd.gov](mailto:ahill@howardcountymd.gov)  
410.313.2455  
410.313.3322 (fax)

To check the status of a permit, please visit [myhoward.info](http://myhoward.info) and search by address or permit number

To request a Use and Occupancy Certificate, please email [uo@howardcountymd.gov](mailto:uo@howardcountymd.gov)

For general inquiries, please email [buildingtech@howardcountymd.gov](mailto:buildingtech@howardcountymd.gov) to ensure a prompt response by all technicians

**From:** Matt Young <matt@revolutionsolar.energy>  
**Sent:** Monday, December 14, 2020 12:25 PM  
**To:** Whalen, Debbie <dwhalen@howardcountymd.gov>  
**Cc:** Hill, Amanda <ahill@howardcountymd.gov>  
**Subject:** RE: 10746 Judy Lane

[Note: This email originated from outside of the organization. Please only click on links or attachments if you know the sender.]

Hi Debbie, yes thanks. I filled out the attached form, is this the correct pool affidavit? Do I need to reapply or come in to add the description? Here is the description.

“Install new second story deck and in ground pool and spa with 6’ perimeter fence as per code.”

I also attached a plot plan, please let me know if this is sufficient.

Thanks,  
Matt

**From:** Whalen, Debbie <[dwhalen@howardcountymd.gov](mailto:dwhalen@howardcountymd.gov)>

**Sent:** Monday, December 14, 2020 10:19 AM

**To:** Matt Young <[matt@revolutionsolar.energy](mailto:matt@revolutionsolar.energy)>

**Cc:** Hill, Amanda <[ahill@howardcountymd.gov](mailto:ahill@howardcountymd.gov)>

**Subject:** 10746 Judy Lane

Hi Matt,

We are in receipt of the permit for the above property. However, there is not a description of work filled out on the application. The drawings attached seem to indicate two things – a pool and a deck.

If it is either one (or both), we need a plot plan showing the property lines and the scope of work drawn on it to scale with dimensions. If it is a pool, there is also a pool affidavit that also needs to be completed and signed.

Please advise,

Debbie Whalen, Plan Review Division  
Inspections, Licenses and Permits

DEPARTMENT OF INSPECTIONS, LICENSES AND PERMITS

HOWARD COUNTY MARYLAND

**WATER SHALL NOT BE PLACED INTO THE POOL UNTIL A FINAL BUILDING INSPECTION IS APPROVED**

**THE FINAL INSPECTION WILL NOT BE APPROVED UNTIL ALL REQUIRED SWIMMING POOL SAFETY DEVICES ARE INSTALLED AND FULLY OPERATIONAL**

All Swimming Pools are required to have an Electrical Permit by a Licensed Electrician

Gas Fired Pool Heaters

NO  YES - Plumbing Permit required by a Licensed Plumber / Gas Fitter

DECLARATION OF INTENT TO INSTALL SWIMMING POOL SAFETY DEVICES

Date 12/14/2020 Building Permit # B20 004420 Address 10746 Judy Ln. Columbia MD 21044

The undersigned, being the owner(s) of the above referenced property, hereby accept(s) the responsibility for the installation of an approved fence and safety devices required by Section 3109 of the 2018 Edition of the International Building Code. I (We) agree that the approved minimum 48" high fence and approved safety devices shall be installed prior to the placement of any water in the pool and that fences shall comply with the setback requirements of the Department of Planning and Zoning.

Anna Young Anna Young 10746 Judy Ln. Columbia MD 21044  
Owner(s) Address

Matthew Young Matthew Young 10746 Judy Ln. Columbia MD 21044  
Witness Address

Please call the Plan Review Division (Department of Inspections, Licenses and Permits) at 410-313-2436 for information regarding the fence design or safety devices. For information regarding fence setback requirements, please call the Zoning Administration (Department of Planning and Zoning) at 410-313-2393. Copy of Section 3109 of The International Building Code is on reverse side for your information.

## 2018 INTERNATIONAL RESIDENTIAL CODE SECTION R326

### AND INTERNATIONAL BUILDING CODE SECTION 3109 BARRIER REQUIREMENTS

**3109.1 General.** Swimming pools shall comply with the requirements of Sections 3109.2 through 3109.5 and other applicable requirements of the code.

**3109.3 Public swimming pools.** Public swimming pools shall be completely enclosed by a fence not less than 4 feet (1290 mm) in height or a screen enclosure. Openings in the fence shall not *permit* the passage of a 4-inch-diameter (102mm) sphere. The fence or screen enclosure shall be equipped with self-closing and self-latching gates.

#### **3109.4 Residential swimming pools.**

Residential swimming pools shall be completely enclosed by a barrier complying with Sections 3109.4.1 through 3109.4.3.

**Exception:** A swimming pool with a power safety cover or a spa with a safety cover complying with ASTM F 1346 need not comply with this section.

**3109.4.1 Barrier height and clearances.** The top of the barrier shall be at least 48 inches (1219 mm) above grade measured on the side of the barrier which faces away from the swimming pool. The maximum vertical clearance between grade and the bottom of the barrier shall be 2 inches (51mm) measured on the side of the barrier which faces away from the swimming pool. Where the top of the pool structure is above grade, such as an above-ground pool, the barrier may be at ground level, such as the pool structure or mounted on top of the pool structure. Where the barrier is mounted on top of the pool structure, the maximum vertical clearance between the top of the pool structure and the bottom of the barrier shall be 4 inches (102mm).

**3109.4.1.1 Openings.** Openings in the barrier shall not allow passage of a 4-inch-diameter (102 mm) sphere.

**3109.4.1.2 Solid barrier surfaces.** Solid barriers which do not have openings shall not contain indentations or protrusions except for normal construction tolerances and tooled masonry joints.

#### **3109.4.1.3 Closely spaced horizontal members.**

Where the barrier is composed of horizontal and vertical members and the distance between the tops of the horizontal members is less than 45 inches (1143 mm), the horizontal members shall be located on the swimming pool side of the fence. Spacing between vertical members shall be not greater than 1½ inches (44 mm) in width. Where there are decorative cutouts within vertical members, spacing within

the cutouts shall be not greater than 1½ inches (44 mm) in width.

#### **3109.4.1.4 Widely spaced horizontal members.**

Where the barrier is composed of horizontal and vertical members and the distance between the tops of the horizontal members is 45 inches (1143 mm) or more, spacing between vertical members shall be not greater than 4 inches (102 mm). Where there are decorative cutouts within vertical members, spacing within the cutouts shall be not greater than 1½ inches (44 mm) in width.

**3109.4.1.5 Chain link dimension.** Mesh size for chain link fences shall be not greater than a 2½ inch square (57 mm square) unless the fence is provided with slats fastened at the top or the bottom that reduce the opening to not more than 1½ inches (44 mm).

**3109.4.1.6 Diagonal members.** Where the barrier is composed of diagonal members, the opening formed by the diagonal members shall be not greater than 1½ inches (44 mm).

**3109.4.1.7 Gates.** Access doors or gates shall comply with the requirements of Section 3109.4.1.1 through 3109.4.1.6, and shall be equipped to accommodate a locking device. Pedestrian access gates shall open outward away from the pool and shall be self-closing and have a self-latching device. Doors or gates other than pedestrian access doors or gates shall have a self-latching device. Release mechanisms shall be in accordance with Sections 1010.1.9 and 1109.13. Where the release mechanism of the self-latching device is located less than 54 inches (1372 mm) from the bottom of the door or gate, the release mechanism shall be located on the pool side of the door or gate 3 inches (76 mm) or more, below the top of the door or gate, and the door or gate and barrier shall be without opening larger than ½ inch (13 mm) within 18 inches (457 mm) of the release mechanism.

**3109.4.1.8 Dwelling wall as a barrier.** Where a wall of a dwelling serves as part of the barrier, one of the following shall apply:

1. Doors with direct access to the pool through that wall shall be equipped with an alarm which produces an audible warning when the door and/or its screen, if present, are opened. The alarm shall be listed and labeled in accordance with UL 2017. In dwellings not required to be *Accessible units, Type A units or Type B units*, the deactivation switch shall be located 54 inches (1372 mm) or more above the threshold of the door. In dwellings required to be *Accessible units, Type A units or Type B units*, the deactivation switch shall be located no higher than 54 inches (1372 mm) and not less

than 48 inches (1219 mm) above the threshold of the door.

2. The pool shall be equipped with a powered safety cover in compliance with ASTM F 1346; or

3. Other means of protection, such as self-closing doors with self-latching devices, which are approved, shall be acceptable so long as the degree of protection afforded is not less than the protection afforded by Item 1 or 2 described above.

**3109.4.1.9 Pool Structures as Barriers.** Where an above-ground pool structure is used as a barrier or where the barrier is mounted on top of the pool structure, and the means of access is a ladder or steps, then the ladder or steps shall be capable of being secured, locked or removed to prevent access, or the ladder or steps shall be surrounded by a barrier which meets the requirement of Section 3109.4.1.1 through 3109.4.1.8. Where the ladder or steps are secured, locked or removed, any opening created shall not allow the passage of a 4 – inch diameter (102 mm) sphere.

**3109.4.2 Indoor swimming pool.** Walls surrounding an indoor swimming pool shall not be required to comply with Section 3109.4.1.8.


**3109.4.3 Prohibited locations.** Barriers shall be located to prohibit permanent structures, equipment or similar objects from being used to climb the barriers.

**3109.5 Entrapment Avoidance.** Suction outlets shall be designed and installed in accordance with ANSI/APSP-7.

**R326.1 SWIMMING POOLS AND BARRIER REQUIREMENTS.** The requirements of IBC Section 3109 shall apply for design and installation of swimming pools and barriers.



PT 2x12 JOISTS @ 12' o/c




2'-6"

7'-3"

PT 6x6 (TYP DF 4)


TRIPLE 2x12 BEAM

2x12's @ 12' o/c



Existing House

24'



N. 07° 38' 00" E.

267.00

20'

52.40

40'

ION

FRAMING PLAN

SCALE: 1/2" = 1'-0"

19'-10"

Spa Width: 8'  
Spa Length: 10'  
Spa Depth: 3'4"  
Spa Capacity: 600 gal  
Spa Water Area: 63'  
Spa Perimeter: 32'

Pool Width: 16'  
Pool Length: 38'  
Pool's Shallow Depth: 3'6"  
Pool's Maximum Depth: 5'10"  
Pool Capacity: 17,500 gal  
Pool Water Surface Area: 555'  
Pool Perimeter: 104'

38'

77'-2"

6' FENCE WITH MAGNOLIA GATES

CK GATES

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

E

PERMIT NUMBER: B20004420

DATE ACCEPTED:

DEC 11 2020

LICENSES & PERMITS DIVISION



RESIDENTIAL BUILDING PERMIT APPLICATION

HOWARD COUNTY DEPARTMENT OF INSPECTIONS, LICENSES, AND PERMITS

3430 COURT HOUSE DRIVE, ELLICOTT CITY, MD 21043 - PHONE: (410) 313-2455 OPTION #4 www.howardcountymd.gov

BUILDING SITE ADDRESS REQUIRED

Street Address: 10746 Judy Ln. Unit: City: Columbia State: MD Zip Code: 21044 Subdivision/Village/Complex Name: SDP/WP/BA #: Lot: 6 Tax Map: 41 Parcel: Grading Permit #:

DESCRIPTION OF WORK REQUIRED

Existing Use: SFD Proposed Use: SFD Estimated Cost: \$65,000 Trade Work to Be Completed (Separate Permits Required): Mechanical (HVACR) Electrical Plumbing None

PROPERTY OWNER INFORMATION REQUIRED

Owner(s) Name(s) (As it appears on tax records): Anna and Matthew Young Primary Residence: Yes No Owner's Street Address: 10746 Judy Ln. City: Columbia State: MD Zip Code: 21044 Phone: 443 865 5039 Email: MattYoungARL@gmail.com

APPLICANT NAME REQUIRED - INDIVIDUAL WHO SIGNS THIS APPLICATION

Business Name: Revolution Solar Contact Name: Matthew Young Street Address: 10746 Judy Ln. City: Columbia State: MD Zip Code: 21044 Phone: 443 865 5039 Email: Matt@RevolutionSolar.energy

CONTRACTOR INFORMATION REQUIRED

Business Name: Revolution Solar LLC Licensee's Name: Matthew Young License #: 101139 Street Address: 10746 Judy Ln. City: Columbia State: MD Zip Code: 21044 Phone: 443 865 5039 Email: Matt@RevolutionSolar.energy

ARCHITECT/ENGINEER INFORMATION INDIVIDUAL WHO SIGNED PLANS, IF APPLICABLE

Business Name: Name: Street Address: City: State: Zip Code: Phone: Email:

BUILDING CHARACTERISTICS REQUIRED

Primary Structure: SF Dwelling SF Townhouse SF Duplex Mobile Home Multi-Family Dwelling (MF\*) Condo: Yes No Utilities: Electric Gas Water Supply: Public Private (Well) Sewage Disposal: Public Private (Septic) Heating System: Electric Natural Gas Propane Other: Roadside Tree Project: No Yes: # Sprinkler System: NFPA 13 NFPA 13R NFPA 13D None Fire Alarm System: Yes No Voice Evac

ADDITIONAL RESIDENTIAL INFORMATION (PLEASE SELECT/COMPLETE ALL THAT APPLY)

Model Name & Options: # of Bedrooms (SF): 4 # of efficiency units (MF\*): # of 1 BR (MF\*): # of 2 BR (MF\*): # of 3 BR (MF\*): # Rooms: 4 # Full Baths: 3 # Half Baths: 1 # Fireplaces: 1 Garage/Carport Info: Attached Garage Detached Garage Integral Garage Carport None Basement/Foundation Info: Slab on Grade Post & Pier Unfinished Basement Finished Basement: Full or Partial 1st Fl Width: 60 1st Fl Depth: 45 2nd Fl Width: 60 2nd Fl Depth: 45 Bsmt Width: 45 Bsmt Depth: 10' Energy Method: Prescriptive Performance UA Alternative ERI Gross Area: 3800 sq ft Occupiable Area: 3800 sq ft

AGREEMENT/ DISCALIMER REQUIRED

THE UNDERSIGNED HEREBY CERTIFIES AND AGREES AS FOLLOWS: (1) THAT HE/SHE IS AUTHORIZED TO MAKE THIS APPLICATION; (2) THAT THE INFORMATION IS CORRECT; (3) THAT HE/SHE WILL COMPLY WITH ALL REGULATIONS OF HOWARD COUNTY WHICH ARE APPLICABLE THERETO; (4) THAT HE/SHE WILL PERFORM NO WORK ON THE ABOVE REFERENCED PROPERTY NOT SPECIFICALLY DESCRIBED IN THIS APPLICATION; (5) THAT HE/SHE GRANTS COUNTY OFFICIALS THE RIGHT TO ENTER ONTO THIS PROPERTY FOR THE PURPOSE OF INSPECTING THE WORK PERMITTED AND POSTING NOTICES.

APPLICANT'S ORIGINAL SIGNATURE DATE SIGNED 12/11/2020

FOR OFFICE USE ONLY

CHECKS PAYABLE TO: DIRECTOR OF FINANCE OF HOWARD COUNTY

AGENCIES REQUIRED/APPROVALS: PR DPZ DED Health SHA CID SUBMITTAL FEES: \$275.00 PAYMENT: \*NONE SUBMITTED ACCEPTED BY: DROPPBOX