

00 fee received
4/5/90 A.S.A.P
Thursday
12:00
Note inspected 4:00 PM

03-284964

File

D.P.C.O. 4/5/90
D.P.C.O. 4/5/90
P 45784

PERMIT

SEWAGE DISPOSAL SYSTEM

MARYLAND STATE DEPARTMENT OF HEALTH DISTRICT

HOWARD COUNTY
BUREAU OF ENVIRONMENTAL HEALTH
461-9933

A REPAIR

DATE 04/17/90
04/05/90

DATE SYSTEM APPROVED 4/5/90

INSPECTOR C.B.W.

INDEXED

W. R. F & Son, Plumbing & Heating IS PERMITTED TO INSTALL ALTER

ADDRESS 15 N. Main Street, Mt. Airy, Maryland 21771 PHONE 829-1711

SUBDIVISION ROAD 12490 Indian Hill Dr. LOT

PROPERTY OWNER Dorothy Youse
12490 Indian Hill Drive

ADDRESS Sykesville, Maryland 21784

~~EXCHANGE OR UNDER IS USED IN ONE TANK SYSTEM CAPACITY BY BOX AND AGE OF SYSTEM~~

~~EXCHANGE OR UNDER IS USED IN ONE TANK SYSTEM CAPACITY BY BOX AND AGE OF SYSTEM~~

① Note - 13' ± deep
see back

SEPTIC TANK CAPACITY GALLONS NUMBER OF BEDROOMS

REPAIR - CALL FOR INSPECTION WHEN GROUND IS OPENED SO SANITARIAN CAN RECOMMEND REPAIR.

4/5/90 Trench 65' Long, 2' wide; depth 9' ± 10' - 10 1/2' (5' + stones under pipes)

PLANS APPROVED BY Craig Williams DATE 04/05/90

COVER NO WORK UNTIL INSPECTED AND APPROVED

NEITHER THE HOWARD COUNTY COUNCIL NOR THE HEALTH DEPARTMENT IS RESPONSIBLE FOR THE SUCCESSFUL OPERATION OF ANY SYSTEM

NOTE: CLEANOUT REQUIRED EVERY 70 FEET OF SEWER LINE AND/OR AT 90° SWEEPS IN LINES FROM HOUSE TO DRAIN FIELDS

NOTE: ALL PARTS OF SEPTIC SYSTEMS (I.E. TANK, DISTRIBUTION BOX, TRENCHES) TO BE 100 FEET FROM WELL (UNLESS OTHERWISE SPECIFICALLY AUTHORIZED)

NOTE: IF DEEP TRENCHES ARE USED CALL FOR INSPECTION BEFORE AND AFTER PLACING GRAVEL IN TRENCHES

NOTE: NO DRY WELL SHALL EXCEED 15 FOOT IN DIAMETER NO ABSORPTION TRENCH TO EXCEED 100 FEET IN LENGTH

NOTE: ALL PIPE FROM HOUSE TO SEPTIC TANK MUST BE CAST IRON OR SCHEDULE 40 PVC OR ABS

PERMIT VOID AFTER TWO YEARS

NOTE: INSTALL STAND PIPE ON SEPTIC TANK AND DRY WELL STAND PIPES MUST BE 6 INCHES IN DIAMETER CAST IRON, CONCRETE OR TERRA COTTA OR PVC OR ABS ACCEPTED. IF TOP OF SEPTIC TANK IS DEEPER THAN 3 FEET, MANHOLE TO GRADE REQUIRED

NOTE: DISTRIBUTION BOXES MUST HAVE BAFFLES

*INSTALLER IS RESPONSIBLE FOR OBTAINING FINAL APROVAL ON THIS PERMIT

*CALL 461-9933 FOR INSPECTION OF SEPTIC SYSTEMS.

45784

